

View Enquiry: BE 2018-6019-002**Contract Details**

Contract Number	2018-6019		
Region	Northwestern	Tender Owner	MTO Capital
Location	Highway 602 at La Vallee River Bridge 9.8km West of Highway 611 (Site No. 45X-0085/B0)	Highway	602
Length	0		
QMS Declaration	Yes	Option A or B bidding	No

Contract Description

Structural, Grading,
Drainage, Granular Base, and Hot Mix Paving Length: 0.28 Km

Tender Instructions**Contract Dates**

Tender Advertise	05-Dec-2018
Tender Opening	15-Jan-2019 at 01:30:00 PM
TRF Submission Opening	18-Dec-2018
TRF Submission Closing	11-Jan-2019 at 12:00:00 PM

Enquiry Details

Enquiry Date	21-Dec-2018 at 10:41:33 AM
Type	Contract Drawing
Subject	Steel grade

Enquiry

Drawing sheet 15
(2018-6019 Contract Drawings Book 1 of 1) Note 2, This note specifies that structural steel charpy impact energy requirements shall be 27 Joules @ -35°C. Would it be acceptable to use Category 3 steel with charpy impact energy requirements of 27 Joules @ -30°C? Thank you.

Response Details

Response Status	Completed
Response Date	02-Jan-2019 at 11:34:58 AM

Response

Yes it would be acceptable to utilize Category 3 steel with charpy impact energy requirement of 27 joules at -30C.

Modification History

Entered by rlapointe on 21-Dec-2018 at 10:41:33 AM
Last modified by srikhi on 02-Jan-2019 at 11:34:59 AM