

**View Enquiry: BE 2018-6019-003****Contract Details**

Contract Number	2018-6019		
Region	Northwestern	Tender Owner	MTO Capital
Location	Highway 602 at La Vallee River Bridge 9.8km West of Highway 611 (Site No. 45X-0085/B0)	Highway	602
Length	0		
QMS Declaration	Yes	Option A or B bidding	No

**Contract Description**

Structural, Grading,  
Drainage, Granular Base, and Hot Mix Paving Length: 0.28 Km

**Tender Instructions****Contract Dates**

Tender Advertise	05-Dec-2018
Tender Opening	15-Jan-2019 at 01:30:00 PM
TRF Submission Opening	18-Dec-2018
TRF Submission Closing	11-Jan-2019 at 12:00:00 PM

**Enquiry Details**

Enquiry Date	28-Dec-2018 at 04:40:52 PM
Type	Other
Subject	Sandblasting Steel

**Enquiry**

Note 14 on Sheet 15 of the contract drawings states all 350A steel shall be blast cleaned before installation. Is this only the areas on the steel that is to be painted or spliced?

**Response Details**

Response Status	Completed
Response Date	02-Jan-2019 at 11:35:34 AM

**Response**

All the areas on steel plates need to be blast cleaned before fabrication.

**Modification History**

Entered by tsharp on 28-Dec-2018 at 04:40:52 PM  
Last modified by srikhi on 02-Jan-2019 at 11:35:35 AM