

View Enquiry: BE 2018-6019-004**Contract Details**

Contract Number	2018-6019		
Region	Northwestern	Tender Owner	MTO Capital
Location	Highway 602 at La Vallee River Bridge 9.8km West of Highway 611 (Site No. 45X-0085/B0)	Highway	602
Length	0		
QMS Declaration	Yes	Option A or B bidding	No

Contract Description

Structural, Grading,
Drainage, Granular Base, and Hot Mix Paving Length: 0.28 Km

Tender Instructions**Contract Dates**

Tender Advertise	05-Dec-2018
Tender Opening	15-Jan-2019 at 01:30:00 PM
TRF Submission Opening	18-Dec-2018
TRF Submission Closing	11-Jan-2019 at 12:00:00 PM

Enquiry Details

Enquiry Date	28-Dec-2018 at 04:43:04 PM
Type	Other
Subject	Levelling Device and EVA Foam

Enquiry

Note 4 on Sheet 20 of the contract drawings indicates the height of the EVA Foam varies. Is there a minimum thickness for the EVA Foam? This information is required to calculate ductal volumes.

Response Details

Response Status	Completed
Response Date	07-Jan-2019 at 11:41:15 AM

Response

For quantity calculation purposes thickness of EVA foam can be considered 50mm. It will vary along the length of the girders.

Modification History

Entered by tsharp on 28-Dec-2018 at 04:43:04 PM
Last modified by Iniyonkuru on 07-Jan-2019 at 11:41:18 AM