

City of Ottawa
Supply Services
100 Constellation Drive
4th Floor, West Tower
Ottawa, Ontario K2G 6J8
Fax: (613) 560-2126
Telephone: (613) 580-2424



Ville d'Ottawa
Services de l'approvisionnement
100, promenade Constellation
4^e étage, tour Ouest
Ottawa, Ontario K2G 6J8
Fax: (613) 560-2126
Téléphone: (613) 580-2424

ADDENDUM # 2

Contract 36521-91360-T02 # CP000546 REHABILITATION OF FOUR FLOW THROUGH PUMP STATIONS

Date: November 1, 2021

The following modifications and clarifications are to be made and taken into consideration when tendering on this contract and when entering into the Form of Agreement to do the work they shall become a part thereof.

INSTRUCTIONS

- Bidders are reminded to review Spec 01200. Submission of appropriate product material is required for informed review/decision if alternate products are proposed as equivalent. Submission of alternate products must follow Spec 01200 Part 2 Section 2.1. Unapproved products shall not be considered outside tender period

ANSWERS TO QUESTIONS ASKED BY TENDERERS

Question 1:

Section 16223, clause 2.1.7.3 – could you please advise if you will accept a Danfoss FC-202 VLT Aqua drive as an approved alternate? This VFD is purpose built for 1-phase input application (not a de-rated 3-phase unit) and perfect for lift stations or other pumping applications where 3-phase power is not available. Please see attached brochure for details. We are a factory-certified Danfoss partner and we can provide a full suite of supporting services such as extended warranties, service contracts, start-up and commissioning, spare parts, repairs, and training.

Answer 1:

Danfoss VFD is not acceptable as an alternative.

Question 2:

Section 16238 (Power Generation – Natural Gas) appears to be missing entirely. Could you please advise and release via addendum? It is shown in Division 16 summary but nowhere else.

Answer 2:

See Addendum #1.

Receipt of this addendum shall be acknowledged on page A-12 of the Tender. Failure to do so may result in the rejection of your Tender submission.

For further information, please contact Julie-Ann Williams, Procurement Officer, Supply Services at 613 580-2424 ext. 15102.