



ADDENDUM #4

36521-91345-T06

Laporte and Leonard WWPS Reliability Upgrade

Date: December 23, 2021

The Following modifications and clarifications are to be made and taken into consideration for the above referenced RFT and shall become a part of any resulting contract.

Instructions:

1. Replace Leonard E205 Revision 3 with E205 Revision 4.

Clarification:

Questions & Answers:

Q1. Can the Thompson Automatic transfer switch, controller and manual transfer switch be approved for use? The Breaker operated ATS is equal to the Eaton model and has been installed at multiple City sites including Greenbank and Chapel Hill Pumpstations and Barrhaven Reservoirs to name a few.

A1: Thomson TS870 is an acceptable alternative. Any Additional costs associated with the integration of the Thomson TS870 with the tendered design shall be fully borne by the Contractor at their own expense.

Q2. Section 13000, 3.3 states that manufacturer services are required for only the Ultrasonic and Laser level instruments, but 13000, 3.11 states that factory trained technicians are required to do training on all devices and instruments. Are factory trained technicians required to provide training on the instruments and devices listed in 2.2.3/.4/.5/.6/.8? Many of those devices do not offer factory services due to the simplicity of the devices.

A2: Acceptable to provide training for the forcemain pressure transmitter, temperature transmitter, security key switch, magnetic door contacts, and float switch from a certified third party.

Q3. As per the drawings the topsoiled areas are to be hydroseeded. There appears to be no sodding shown or required. Please confirm.

A3: Bid shall be based on works shown on drawings.

Q4: Section 2.2.11(in both specs) – Please confirm thermistors in the alternator are required. This is a stand-by application, and not typical on a unit of this size. If temperature monitoring is required, this will result in a oversized alternator and elevated availability of fault current.

A4: Thermistors in the alternator are not required.

This addendum forms part of the Request for Tender. In your Form of Tender, please indicate receipt thereof, failure to do so may result in the rejection of the tender submission.

For further information, please contact Julie-Ann Williams, Procurement Officer, Supply Services at Julie-Ann.Williams@ottawa.ca.

End of Addendum #4